



China

Choose certainty.
Add value.

Gulf Security Technology Co., Ltd.
No. 80, Changjiang East Road, QETDZ
066004 Qinhuangdao, Hebei
PEOPLE'S REPUBLIC OF CHINA

Addressable Gas Detector

Project number	Technical certifier	Tel. extension/e-mail	Fax extension	Date	Page
BJ8001023101	Ms. Zhang Jing	+86 10 65906186-304 Jing.zhang@tuv-sud.cn	+86 1065906182	12 October 2010	1

E8N Attestation of conformity(CE EMC)

We are pleased to attach your certificate of Conformity (No.: E8N 10 10 60192 004), which confirm that a sample of the above mentioned technical equipment has been tested and was found to be in accordance with the relevant requirements.

Let us herewith give you some additional information which we consider to be important to you:

- The product has to be accompanied by a user manual and safety labelling/warning mark in the language of the country where it is supposed to be sold.
- To ensure that the validity of the certificate, please control any change in your production or of the product by yourself.
- Declaration of conformity and CE marking and should be prepared with the product to be sold to EU market according to related EU regulation and directives.
- Other related EU regulation and directives for the product should also be met with.

We appreciate your kind support and would like to offer our assistance and continuous services at any time.

Yours sincerely,


Jing Zhang

Technical certifier/ TÜV SÜD Product service, CRT3

HSBC Bank (China) Company Limited, Beijing Branch

Account No: CNY 626-228472-011
USD 006-228472-055
EUR 006-228472-056

HSBCCNSHBJG

Telephone: +86 10 6590 6186
Telefax: +86 10 6590 6182
www.tuv-sud.cn

TUV®

TÜV SÜD China, Beijing Branch
9th Floor, Landmark Tower 2
8 North Dongsanhuan Road
Beijing 100 004
P.R. China



Product Service

Attestation of Compliance

No. E8N 10 10 60192 004

Holder of Certificate: Gulf Security Technology Co., Ltd.

No. 80, Changjiang East Road, QETDZ
066004 Qinhuangdao, Hebei
PEOPLE'S REPUBLIC OF CHINA

Name of Object: gas detection systems
Addressable Gas Detector

Model(s): I-9602LW, I-9602LW-NG

Description of Object:	Rated voltage:	24VDC
	Rated power:	3W (Alarm state) 0.5W (Quiescent state)
	Protection class:	III
	Detecting gas:	Natural Gas
	Alarm Density:	6% LEL (Methane)
	Apparatus type:	Type 1

Tested according to: EN 50270:2006, Type 1

This Attestation of Compliance is issued according to the Directive 2004/108/EC relating to electromagnetic compatibility on a voluntary basis. It confirms that the listed apparatus complies with all essential requirements of the EMC directive and applies only to the sample and its technical documentation submitted to TÜV SÜD Product Service GmbH for testing and certification. See also notes overleaf.

Test report no.: BJ8001023101


(Jing Zhang)

Date, 2010-10-11



CE After preparation of the necessary technical documentation as well as the EC conformity declaration the required CE marking can be affixed on the product. Other relevant directives have to be observed.

Page 1 of 1