

Loss Prevention Certification Board



This is to certify

GLOBAL SYSTEM TECHNOLOGY PLC

Lion Court, Staunton Harold Hall, Melbourne Road, Ashby de le Zouch,
Leicestershire, England, LE65 1RT

is authorised to use the LPCB mark in association with the
product(s) listed in this certificate and appendix.

GST 200, GST101, GST102, GST 104, GST108 and GST 116
Control and Indicating Equipment

which have complied with the requirements of the following:

**EN 54-2:1997 – Fire detection and fire alarm systems – Part 2: Control
and indicating equipment.**

**EN 54-4:1997 – Fire detection and fire alarm systems – Part 4: Power
supply equipment**

Certificate No. 548j-(cl-5)

Issue No. 01

Date of Issue 25 October 2007

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: P STEVENS



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 548j-(cl-5)

GLOBAL SYSTEM TECHNOLOGY PLC

Products

LPCB Ref. No.

GST 200 Intelligent 1 loop, 30 zone analogue addressable control and indicating equipment

548j/01

Incorporating the following units:

F7.820.826	Main board
F7.820.827	Switch board
F7.820.828	Loop interface board
F7.820.829	Power supply unit
F7.908.312	Zone indication board
CGM12864	Alphanumeric display
F2.910.093	Mains filter
R150	Transformer
F2.828.630a	Printer board (option)

Incorporating as optional modular units:

F7.820.170	RS-232 board for configuration
P-9901	Printer module kit

Certified with the following options with requirements from EN 54 part 2:

7.8	Output to Fire Alarm Devices
7.10	Output to automatic Fire Protection Equipment
7.11	Delays to outputs
7.12	Coincidence detection
8.3	Fault signals from points
9.5	Disablement of addressable points

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 2 of 4

Date of Issue 25 October 2007

Issue No. 01

Name: P STEVENS

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 548j-(cl-5)

GLOBAL SYSTEM TECHNOLOGY PLC

Products	LPCB Ref. No.
GST 101 Single zone conventional control and indicating equipment	548j/02
Certified with the following options with requirements from EN 54 part 2:	
7.8 Output to Fire Alarm Devices	
10 Test condition	
GST 102 Two zone conventional control and indicating equipment	548j/03
Certified with the following options with requirements from EN 54 part 2:	
7.8 Output to Fire Alarm Devices	
10 Test condition	
GST 104 Four zone conventional control and indicating equipment	548j/04
Certified with the following options with requirements from EN 54 part 2:	
7.8 Output to Fire Alarm Devices	
7.11 Delays to outputs	
10 Test condition	


This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 3 of 4

Date of Issue 25 October 2007

Issue No. 01


Name: P STEVENS

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 548j-(cl-5)

GLOBAL SYSTEM TECHNOLOGY PLC

Products

LPCB Ref. No.

GST 108 Eight zone conventional control and indicating equipment

548j/05

Certified with the following options with requirements from EN 54 part 2:

- 7.8 Output to Fire Alarm Devices
- 7.11 Delays to outputs
- 10 Test condition

GST 116 Sixteen zone conventional control and indicating equipment

548j/06

Certified with the following options with requirements from EN 54 part 2:

- 7.8 Output to Fire Alarm Devices
- 7.11 Delays to outputs
- 10 Test condition

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 4 of 4

Date of Issue 25 October 2007

Issue No. 01

Name: P STEVENS

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.