

Loss Prevention Certification Board



This is to certify

GLOBAL SYSTEM TECHNOLOGY PLC

Lion Court, Staunton Harold Hall, Melbourne Road, Ashby de le Zouch,
Leicestershire, England, LE65 1RT

is authorised to use the LPCB mark in association with the
product(s) listed in this certificate and appendix.

GST200-2 and GST-IFP8 Control and Indicating Equipment

which have complied with the requirements of the following:

**EN 54-2: 1997 + A1: 2006 – Fire detection and fire alarm systems - Control
and indicating equipment**

**EN 54-4: 1997 + A1: 2002 + A2: 2006 – Fire detection and fire alarm systems
- Power supply equipment**

Certificate No. 548p-(cl-1)


Issue No. 02

Date of Issue 04 June 2009

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Name: R WELLS



LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 548p-(cl-1)

GLOBAL SYSTEM TECHNOLOGY PLC

Products

LPCB Ref. No.

GST200-2 Intelligent 2 loop, 30 zone analogue addressable control and indicating equipment

548p/01

Incorporating the following units:

F7.820.826	Main board
F7.820.827	Switch board
F7.820.828	Loop interface board
F7.820.829b	Power supply unit
F7.908.312d	Zone indication and intervention board
F7.820.1125	Loop board

Incorporating as optional modular units:

F7.820.170	RS-232 board for configuration
P-9901	Printer module kit

Certified with the following options with requirements from EN 54 part 2:

7.8	Output to Fire Alarm Devices
7.10.1	Output to automatic Fire Protection Equipment Type A
7.11	Delays to outputs
8.3	Fault signals from points
9.5	Disablement of addressable points

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 2 of 4

Date of Issue 04 June 2009

Issue No. 02

Name: R WELLS

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 548p-(cl-1)

GLOBAL SYSTEM TECHNOLOGY PLC

Products

LPCB Ref. No.

GST-IFP8 Intelligent 8 loop, 140 zone analogue addressable control and indicating equipment

548p/02

Incorporating the following units:

F7.820.1238 Indication board
F7.820.1239 Loop board
F7.820.1311 Power board
F7.820.1312 ZCP board
F7.820.1326 Keypad board
F7.820.1237 Main board
F7.820.1310 Mother board

Incorporating as optional modular units:

F7.820.1313 USB communication board

Continued...

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 3 of 4

Date of Issue 04 June 2009

Issue No. 02

Name: R WELLS

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.

Loss Prevention Certification Board



APPENDIX TO CERTIFICATE NO. 548p-(cl-1)

GLOBAL SYSTEM TECHNOLOGY PLC

Products

LPCB Ref. No.

Certified with the following options with requirements from EN 54 Part 2:

- 7.8 Output to fire alarm devices
- 7.9.1 Output to fire routing equipment
- 7.9.2 Alarm confirmation input from fire routing equipment
- 7.10.1 Output type A
- 7.10.2 Output type B
- 7.10.4 Fault monitoring of fire protection equipment
- 7.11 Delays to outputs
- 7.12.1 Dependencies on more than one alarm signal – Type A
- 7.12.2 Dependencies on more than one alarm signal – Type B
- 7.13 Alarm counter
- 8.3 Fault signals from points
- 9.5 Disablement of each address point
- 10 Test condition

This certificate is valid until withdrawn by LPCB.
To check the validity and the authenticity of this certificate please
visit our website www.RedBookLive.com or contact us.

Signed on behalf of the LPCB

Page 4 of 4

Date of Issue 04 June 2009

Issue No. 02

Name: R WELLS

LPCB is part of BRE Certification Ltd., Garston, Watford WD25 9XX. Tel +44 (0)1923 664100
Fax +44 (0)1923 664603 www.RedBookLive.com

This certificate remains the property of BRE Certification Ltd and is issued subject to terms and conditions
and is maintained and held in force through regular surveillance activities.