

UROX2.S8578
Smoke-automatic Fire Detectors - Component

[Page Bottom](#)

Smoke-automatic Fire Detectors - Component

[See General Information for Smoke-automatic Fire Detectors - Component](#)

GULF SECURITY TECHNOLOGY CO LTD

S8578

NO 80 CHANGJIANG EAST RD, QETDZ
QINHUANGDAO, HEBEI 066004 CHINA

| Detector | | | Compatibility | Velocity Range (fpm) | |
|-----------------------------------|-------------|------|---------------|----------------------|-----|
| Model | Application | Type | Restrictions | Min | Max |
| I-9102 (UL), JTY-GD-G3 | OAP | P | D5 | 0 | 300 |
| JTY-GF-GST104, C-9102 (UL) | OAP | P | D5 | 0 | 300 |

| Base Model | Related Detector | Control Unit Compatibility Restrictions |
|--------------|--|---|
| DZ-03 | JTY-GF-GST104, JTY-GD-G3, I-9102 (UL), C-9102 (UL) | B5 |

B5 - For use only with Listed control units with which compatibility was determined by test.

D5 - For use only with Listed control units with which compatibility was determined by test.

OAP - Open Area Protection

P - Photoelectric

Marking: Company name and model designation.

[Last Updated](#) on 2009-05-05

[Questions?](#)

[Notice of Disclaimer](#)

[Page Top](#)

Copyright © 2009 Underwriters Laboratories Inc.®

The appearance of a company's name or product in this database does not in itself assure that products so identified have been manufactured under UL's Follow-Up Service. Only those products bearing the UL Mark should be considered to be Listed and covered under UL's Follow-Up Service. Always look for the Mark on the product.

UL permits the reproduction of the material contained in the Online Certification Directory subject to the following conditions: 1. The Guide Information, Designs and/or Listings (files) must be presented in their entirety and in a non-misleading manner, without any

manipulation of the data (or drawings). 2. The statement "Reprinted from the Online Certifications Directory with permission from Underwriters Laboratories Inc." must appear adjacent to the extracted material. In addition, the reprinted material must include a copyright notice in the following format: "Copyright © 2009 Underwriters Laboratories Inc.®"